

L:1 A:27

I & C MONITOR CALIBRATION

03/17/20
12:30:01

Sample Press 0.00E+00 XRE5570A No description XRE5570A
no cal no cal desc

Sample Flow1 1.00E+00
Sample Flow2 0.00E+00

[Refresh]

Activity	CPM	
PVG		■MONITOR OFFLINE..... ON LINE
084 4.75E-06√ 4.78E-04		■MONITOR COMMUNICATIONS FAILURE.....
		■CHANNEL NOT RESPONDING TO POLL.....
PVG		■MONITOR DATA BASE UNKNOWN.....
484 4.75E-06√ 6.53E-02		■MONITOR LOSS OF SAMPLE FLOW.....
		■CHANNEL OUT OF SERVICE.....
		■CHANNEL FILTER NOT MOVING.....
		■CHANNEL FILTER CLOGGED.....
		■CHANNEL NO PULSES RECEIVED.....
PVG		■CHANNEL CHECK SOURCE TEST FAILED....
584 4.75E-06√ 4.84E-06		■CHANNEL LOSS OF SAMPLE FLOW..... 02 03
		■CHANNEL HIGH TEMPERATURE CONDITION..
PVF		■CHANNEL OPERATE FAILURE.....
684 7.67E+03√ 2.31E+11		
		■CHANNEL IN HIGH ALARM.....
		■CHANNEL IN ALERT ALARM.....

PROCEDURE STATUS No Cal Loaded

RM80 POLL STATUS ON LINE

PURGE INACTIVE

FLOW ACTIVE

Function Inhibit Switches

S9	S10	S11
DB on	on	DB on
LOAD OFF	CONTR OFF	ALTER OFF
ENABLE	ENABLE	ENABLE

■MONITOR PURGING.....

■CHANNEL PURGING.....

■CHANNEL CHECK SOURCE ENERGIZED.....

■CHANNEL FILTER ADVANCING.....

■NORMAL OPERATING CONDITION..... 01 04



[ALARMS]

03/17 12:29:50.3 [-AUDIT-] ACK PVG584 DEV STATUS ACKNOWLEDGED by SteveV

03/17 12:29:50.3 [-AUDIT-] ACK PVG484 DEV STATUS ACKNOWLEDGED by SteveV

03/17 12:29:38.7 [SCADA-A] XRE5570A:MI039 CURRENT from 1 to 0

03/17 12:29:37.1 [SCADA-A] XRE5570A:MI001 CURRENT from 11 to 0

03/17 12:29:35.3 [SCADA-A] XRE5570A:MI041 CURRENT from 0 to 63

03/17 12:29:34.7 [SCADA-A] XRE5570A:MI043 CURRENT from 0 to 32

03/17 12:29:34.1 [SCADA-A] XRE5570A:MI059 CURRENT from 6.80E+04 to 1.05E+05

03/17 12:29:31.5 [SCADA-A] PVG084:CI011 CURRENT from 1.00E-02 to 3.40E-08

03/17 12:29:29.7 [SCADA-A] ALM PVG584 DEV RM-80/Channel Operate Failure

03/17 12:29:29.7 [SCADA-A] ALM PVG584 CHANNEL LOSS OF FLOW

03/17 12:29:29.7 [SCADA-A] ALM PVG484 DEV RM-80/Channel Operate Failure

RMCS Control: SCADA-A Connected
Using Arrow Keys to Navigate

SteveV Administrator
SCREEN: Calib